

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Control Corporation

100 5th Ave NW, 55112 New Brighton, MN, USA

the Certificate No: **Z12363** for the PROFINET IO Device:

Model Name: IO-Link Master DR-8-PNIO-P/T
 Revision: SW/FW: V1.5.28; HW: 1
 Identnumber: 0x0163; 0x0010
 GSD: GSDML-V2.34-Comtrol-IO-Link-20181102.xml
 DAP: DAP 6, 0x0000000c

This certificate confirms that the product has successfully passed the certification tests with the following scope:

| | | |
|-------------------------------------|---------------------|--|
| <input checked="" type="checkbox"/> | PNIO_Version | V2.34 |
| <input checked="" type="checkbox"/> | Conformance Class | B |
| <input checked="" type="checkbox"/> | Optional Features | Legacy, MRP |
| <input checked="" type="checkbox"/> | Netload Class | I |
| <input checked="" type="checkbox"/> | PNIO_Tester_Version | V2.35.2.2 |
| <input checked="" type="checkbox"/> | Tester | PROFI Interface Center, Johnson City, USA PN254-1 |

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".


For all products that are placed in circulation by **November 19, 2021** the certificate is valid for life.

Karlsruhe, December 10, 2018

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)




(Dr. Jörg Hähnliche)